



March 30, 2021

Doug Williams
Frameless Hardware Company LLC
4361 Firestone Blvd.
South Gate, CA 90280

Re: Compatibility Testing

Dear Doug,

We are pleased to provide you with the following information regarding recent component compatibility testing in conjunction with OPACI-COAT-300®.

CASE: CAS- 26982-X5M8C3

Description of Product Tested: FHC RTV Silicone, CSB040, and CSB125 Clear Plastic Setting Blocks.

Manufacturer of Product: FHC

Product Received From: FHC

ICD Product to be Tested: OPACI-COAT-300®

FHC RTV Silicone, CSB040, and CSB125 is compatible for direct contact with OPACI-COAT-300®.

Materials submitted were tested for single component compatibility with the above-stated ICD product only. This testing does not determine compatibility in combination with other materials even where those other materials may also be tested and approved for use. Project specific submittals of all glazing materials and consultation with all component manufacturers regarding the suitability of use in combination with all other materials is required.

Please contact me should you have any questions.

Sincerely,

Austin Seely
Technical Service

cc: Jeff Nicholson
Abram Scurlock
Tim Krytenberg